



**CSC BIDS AND AWARDS COMMITTEE (BAC)**

**SUPPLEMENTAL BID BULLETIN NO. 2**

**Addendum No. 2**

**(1) Name of Project:** "Re-bidding on the Procurement of Additional Blade Servers with Storage and Micro Data Center"

**Solicitation No.:** CSC-ITB No. 2018-07 (Rebidding on Blade Servers & MDC)

**PhilGEPS Reference No.:** 5296793

Following the conduct of the Pre-Bid Conference on May 8, 2018 for the aforesaid project, the following were clarified/agreed upon by the CSC-BAC, BAC-Technical Working Group (TWG) Team-A, End-User Office (IRMO) and the participating bidders and the same were issued through this Supplemental Bid Bulletin No. 2 (Addendum No. 2). **Other specifications and requirements indicated in the Technical Specifications (TS)/Manual of Bidding Documents are retained.**

**I. Clarifications / Addendum**

| Item              | Specifications  |   |
|-------------------|---|---|
|                   | From  | To  |
| Micro Data Center | <b>Monitoring</b><br>Local Display: minimum 10' Screen  | <b>Monitoring</b><br>Local Display: minimum 8' Screen   |
|                   | <b>Power Supply</b><br>Power: 220/230V Single Phase (Input/Output)<br>Power Distribution Unit: 230Vac<br>63A with surge protection<br>Backup Time: minimum 15 minutes | <b>Power Supply</b><br>Power: 220/230V Single Phase (Input/Output)<br>Power Distribution Unit: minimum 230Vac<br>40A with surge protection<br>Backup Time: minimum 15 minutes |
|                   | <b>UPS</b><br>Capacity: 3KVA/2.7KW  | <b>UPS</b><br>Capacity: minimum 3KVA/2.7KW  |

| Bidding Activity                         | From                       | To   | Place / Venue  |
|--|----------------------------|--|--|
| Deadline for Submission of Bid Documents | May 23, 2018 at 10:00 a.m. | <b>May 28, 2018 (Monday)</b> at 10:00 a.m. | Designated Bid Box, OFAM 1 <sup>st</sup> Floor, CSC Resource Center Building |
| Eligibility Checking                     | May 23, 2018 at 11:00 a.m. | <b>May 28, 2018 (Monday)</b> at 11:00 a.m. | 2 <sup>nd</sup> Floor, CSC Resource Center Building                          |
| Bid Opening                              | May 23, 2018 at 11:30 a.m. | <b>May 28, 2018 (Monday)</b> at 11:30 a.m. | 2 <sup>nd</sup> Floor, CSC Resource Center Building                          |

**Bawat Kawani, Lingkod Bayani**

These clarifications/revisions are hereby made as an integral part of the Manual of Bidding Documents for the aforesaid project.

Please be guided accordingly.



**ATTY. ARIEL G. RONQUILLO**  
CSC Assistant Commissioner  
CSC-BAC Chairman

May 21, 2018

OFAM/BAC-Secretarial/SBB #2 - TechSpecs and Scheds- Blade Servers.doc/pmg

